




MICROGRIDS II



Optimizing Microgrid Selection and Operation for Data Center Sustainability

by

Chris Marnay

C_Marnay@lbl.gov - +1.510.486.7028 - <http://der.lbl.gov>

20 Oct 2008


HP Labs, Palo Alto CA



Environmental Energy Technologies Division




Outline



- systemic analysis of building energy systems
- Distributed Energy Resources Customer Adoption Model
- data center example



DER-CAM Concept




Copyright 2008, The Regents of the University of California.
 No use is permitted without written permission.
 Please contact Chris Marnay at C_Marnay@lbl.gov
 if you wish to use or reproduce this diagram for any purpose.






DER-CAM Logic







What is DER-CAM?



- Mixed Integer Linear Program (MILP), written in the General Algebraic Modeling System (GAMS®)
- minimizes annual energy costs (or carbon emissions or multiple objectives) of providing services on a microgrid level (typically buildings 250-2000 kW peak)
- produces pure technology neutral optimal results with highly variable run times
- used for more than 5 years by Berkeley Lab and under license by researchers in the US, Germany, Spain, Belgium, Japan, and Australia



SV Data Center



age of building	~3 years
floorspace	616 m ² (~6600 ft ²)
peak load	~1.8 MW
computing load	~800 kW
utilities (no NG load)	PG&E commercial
marginal emissions	140 g/kWh



Available Equipment



discrete

	CM-100	fuel cell
capacity (kW)	100	200
sprint capacity	125	
installed costs (\$/kW)	2400	5005
with heat recovery (\$/kW)	3000	5200
variable maintenance (\$/kWh)	0.02	0.029
efficiency (% HHV)	26	35
lifetime (a)	20	10

only integer installations

continuous

fixed unavoidable costs

	electrical storage (lead acid)	thermal storage	flow battery	absorption chiller	solar thermal	PV
intercept costs (\$)	295	10000	0	20000	1000	1000
capacity (\$/kW or \$/kWh)	193	100	2125/220	127	500	6675
lifetime (a)	5	17	10	15	15	20





Results from 5 Cases




at full current technology costs

	A	B	C	D	E
	do nothing	invest in all technologies	low storage costs and PV incentive of 2.5\$/W	low storage and PV costs (PV incentive 60%)	(PQR) DER switch run
equipment					
Tecogen 100 kW with HX (kW)		0	0	0	1600
switch size (kW)		n/a	n/a	n/a	1788
abs. chiller (kW in terms of electricity)		141	108	116	316
solar thermal collector (kW)	n/a	0	0	0	0
PV (kW)		0	0	1577	0
Electric storage (kWh)		0	13478	6434	0
thermal storage (kWh)		0	0	0	0
annual costs (k\$)					
onsite DG technologies	n/a	3.99	195.51	467.12	249.36
Benefit from switch (\$/kW/a)	n/a	n/a	n/a	n/a	125.00
Total	1480.15	1473.18	1442.59	1422.24	1443.10
% savings compared to do nothing	n/a	0.47	2.54	3.91	2.50
annual energy consumption (GWh)					
electricity	11.42	11.39	11.74	8.91	8.44
NG	0.00	0.23	0.15	0.12	9.14
annual carbon emissions (t/a)					
emissions	1598.92	1606.13	1650.98	1253.97	1632.06
% savings compared to do nothing	n/a	-0.45	-3.26	21.57	-2.07



Electricity Balance Case E (July Weekday)







Electricity Balance C & D

(July Weekday)



Case D



Case C






Conclusion



- DER-CAM provides a technology neutral optimal equipment choice & operating schedule under many possible objectives
- analysis of a Silicon Valley data center shows
 - virtually no options cost effective at full current costs
 - lower cost storage and PV subsidies can make them competitive and lower carbon footprint
 - dramatic PQR results at 125 \$/kW·a reliability value
1.6 MW of on-site generation & absorption cooling
increased carbon footprint (as in most cases)
- DER-CAM approach can be extended to include full? range of technology options and objectives



Thank you!

